National Pollutant Discharge Elimination System (NPDES)
CSO Annual Report
Part of State Form 50546 (R5 / 11-21)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

City:	Waterloo					Page:	1 of 1	Permit Number:	IN0020711
Facility:	Waterloo Waste Pollution Control								
Monitoring Year:	2025								
Design Peak Flow (Hourly) (MGD):	0.42	Design Flow (MGD):	0.369						

Annual Average Dry Weather Flow =	0.19	MGD	194 days
110 % Annual Dry Weather Flow =	0.21	MGD	

CSO Outfall Number	Days Discharging		Total Discharge Volume	
CSO Outfall No.	13		12.33	MG
CSO Outfall No.	0		0	MG
CSO Outfall No.	0		0	MG
CSO Outfall No.	0		0